



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103694/18-02

Page No: 1 of 1

Report No: BFTT/RT-04/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/RT/ASME Rev 6.0
Project :	Carigali-PTTEPI Operating Company Sdn.Bhd. Provision Of E-1310 Bundle Refurbishment	IQI type :	ASTM 1B
Job No:	BFTT 17-643	Film Manufacturer/Type :	FUJI 100/class II
Material:	SA 350 LF2 CL1 + 10mm SS 316L / SA 516 GR 70N + SS 316L	Density :	2.0 - 4.0
Welding Process :	SMAW OVERLAY	Sensitivity:	0.33mm(5 wires visible)
Examination Code :	ASME V	Source to Object Distance :	475mm
Acceptance Code:	ASME Sect. VIII Div.1 2013 Ed.	Source Side of Object to Film Distance:	(38+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
E-1310								
CS - 2 RS (WN-009)	41	3	950	38	6 - 7	NRI	Accept	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Client Representative:

Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103694/18-02

Page No: 1 of 1

Report No: BFTT/RT-05/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/RT/ASME Rev 6.0
Project :	Carigali-PTTEPI Operating Company Sdn.Bhd.	IQI type :	ASTM 1B
	Provision Of E-1310 Bundle Refurbishment	Film Manufacturer/Type :	FUJI 100/class II
Job No:	BFTT 17-643	Density :	2.0 - 4.0
Material:	SA 350 LF2 CL1 + 10mm SS 316L /	Sensitivity:	0.33mm(5 wires visible)
	SA 516 GR 70N + SS 316L	Source to Object Distance :	475mm
Welding Process :	SMAW OVERLAY	Source Side of Object to Film Distance:	(38+3)mm
Examination Code :	ASME V	No of Radiograph(exposure) :	Single Exposure
Acceptance Code:	ASME Sect. VIII Div.1 2013 Ed.	No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
Examination Date:	16 May 2018	Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
E-1310 After Overlay CS - 2 (WN-009)	41	3	950	38	1 - 2 4 - 5 7 - 8 9 - 10 11 - 0	AR AR AR AR AR	Reshoot Reshoot Reshoot Reshoot Reshoot	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Client Representative:

Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103696/18-01

Page No: 1 of 1

Report No: BFTT/RT-07/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Petronas Chemicals Polyethylene Sdn.Bhd. Fabricate Heat Exchanger Shell Part.	IQI type :	ASTM 1B
		Film Manufacturer/Type :	FUJI 100/class II
Job No:	BFTT 18-664	Density :	2.0 - 4.0
Material:	SA 105N / SA 106 GR B	Sensitivity:	0.33mm(5 wires visible)
		Source to Object Distance :	273.1mm
Welding Process :	GTAW / SMAW	Source Side of Object to Film Distance:	(15.09+3)mm
Examination Code :	ASME V	No of Radiograph(exposure) :	Single Exposure
Acceptance Code:	ASME Sect. VIII Div.1 2017 Ed.	No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
Examination Date:	16 May 2018	Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
PE-1-E-844								
S1 - JT1 RS (WN-216)	18.09	3	273.1	15.09	0 - 1 2 - 0	Por Por	Accept Accept	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
IF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Client Representative:

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018

Name:

Date:





Our Ref. : NT/103695/18-02

Page No: 1 of 1
 Report No: BFTT/RT-08/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/RT/ASME Rev 6.0
Project :	Asean Bintulu Fertiliser Provision For Supply Of New Heat Exchanger -81-A001-E04	IQI type :	ASTM 1B
Job No:	BFTT 17-646	Film Manufacturer/Type :	FUJI 100/class II
Material:	SA 105N / SA 234 WPB	Density :	2.0 - 4.0
Welding Process :	GTAW	Sensitivity:	0.33mm(5 wires visible)
Examination Code :	ASME V	Source to Object Distance :	400mm
Acceptance Code:	ASME Sect. VIII Div.1 2015 Ed.	Source Side of Object to Film Distance:	(73)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
81-A001-E04								
N2 - JT.1 (WN-009)	12.53	3	73	9.53	X	Por		Reject
					Y	NRI		Accept

_____ End Of Report _____

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Client Representative: _____

Name: _____
 Date: _____



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103695/18-02

Page No: 1 of 1

Report No: BFTT/RT-09/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/RT/ASME Rev 6.0
Project :	Asean Bintulu Fertiliser Provision For Supply Of New Heat Exchanger -81- A001-E04	IQI type :	ASTM 1B
Job No:	BFTT 17-646	Film Manufacturer/Type :	FUJI 100/class II
Material:	SA 105N / SA 106 GR.B	Density :	2.0 - 4.0
Welding Process :	GTAW / SMAW / SAW	Sensitivity:	0.33mm(5 wires visible)
Examination Code :	ASME V	Source to Object Distance :	355.6mm
Acceptance Code:	ASME Sect. VIII Div.1 2015 Ed.	Source Side of Object to Film Distance:	(11.13+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
81-A001-E04								
CS 5 (WN-009/216)	14.13	3	355.6	11.13	0 - 1	AR Hanger Marks	Reshoot	
					1 - 2	AR Hanger Marks	Reshoot	
					2 - 3	AR Hanger Marks	Reshoot	
					3 - 0	AR Hanger Marks	Reshoot	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Client Representative:

Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103693/18-09

Page No: 1 of 1

Report No: BFTT/RT-16/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd . / PT.Austindo Nusantara Jaya 35,000 KG / HR Boiler.	IQI type :	DIN FE 10-16
Job No:	BFTT 17-651	Film Manufacturer/Type :	FUJI 100/class II
Material:	A106GR.B / A 234 WPB	Density :	2.0 - 4.0
Welding Process :	TIGW / MMAW	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	BS 1435	Source to Object Distance :	273.1mm
Acceptance Code:	BS 1113:1999	Source Side of Object to Film Distance:	(9.27+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
SHC1 - 81020								
JT.3 R1 (WN-090/311)	12.27	3	273.1	9.27	2 - 0	NRI	Accept	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Client Representative:

Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103693/18-09

Page No: 1 of 1

Report No: BFTT/RT-17/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd . / PT.Austindo Nusantara Jaya 35,000 KG / HR Boiler.	IQI type :	DIN FE 10-16
Job No:	BFTT 17-651	Film Manufacturer/Type :	FUJI 100/class II
Material:	A106GR.B / A 234 WPB	Density :	2.0 - 4.0
Welding Process :	TIGW / MMAW	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	BS 1435	Source to Object Distance :	273.1mm
Acceptance Code:	BS 1113:1999	Source Side of Object to Film Distance:	(9.27+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
SHC1 - 81020								
JT.4 (WN-090/311)	12.27	3	273.1	9.27	0 - 1 1 - 2 2 - 0	NRI NRI LF	Accept Accept Reject	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Client Representative:

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103693/18-09

Page No: 1 of 1

Report No: BFTT/RT-18/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd . / PT.Austindo Nusantara Jaya	IQI type :	DIN FE 10-16
Job No:	35,000 KG / HR Boiler.	Film Manufacturer/Type :	FUJI 100/class II
Material:	BFTT 17-651	Density :	2.0 - 4.0
Welding Process :	A106GR.B / A 234 WPB	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	TIGW / MMAW	Source to Object Distance :	273.1mm
Acceptance Code:	BS 1435	Source Side of Object to Film Distance:	(9.27+3)mm
Examination Date:	BS 1113:1999	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
SHC1 - 81020								
JT.5 (WN-090/311)	12.27	3	273.1	9.27	0 - 1	NRI	Accept	
					1 - 2	NRI	Accept	
					2 - 0	NRI	Accept	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Client Representative:

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018

Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103693/18-09

Page No: 1 of 1

Report No: BFTT/RT-19/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd. / PT Austindo Nusantara Jaya	IQI type :	DIN FE 10-16
Job No:	35,000 KG / HR Boiler.	Film Manufacturer/Type :	FUJI 100/class II
Material:	BFTT 17-651	Density :	2.0 - 4.0
Welding Process :	A106GR.B / A 234 WPB	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	TIGW / MMAW	Source to Object Distance :	219.1mm
Acceptance Code:	BS 1435	Source Side of Object to Film Distance:	(8.18±3)mm
Examination Date:	BS 1113:1999	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
MSC - 81020								
JT.3 (WN-302)	11.18	3	219.1	8.18	0 - 1 1 - 2 2 - 0	NRI Por Por	Accept Accept Accept	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Client Representative:

Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103693/18-09

Page No: 1 of 1

Report No: BFTT/RT-20/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd ./ PT.Austindo Nusantara Jaya 35,000 KG / HR Boiler.	IQI type :	DIN FE 10-16
Job No:	BFTT 17-651	Film Manufacturer/Type :	FUJI 100/class II
Material:	A106GR.B / A 234 WPB	Density :	2.0 - 4.0
Welding Process :	TIGW / MMAW	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	BS 1435	Source to Object Distance :	219.1mm
Acceptance Code:	BS 1113:1999	Source Side of Object to Film Distance:	(8.18+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
MSC - 81020								
JT.2 (WN-302)	11.18	3	219.1	8.18	0 - 1	Por		Reject
					1 - 2	Por		Accept
					2 - 0	NRI		Accept

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Client Representative:

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103693/18-09

Page No: 1 of 1

Report No: BFTT/RT-21/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd . / PT.Austindo Nusantara Jaya 35,000 KG / HR Boiler.	IQI type :	DIN FE 10-16
Job No:	BFTT 17-651	Film Manufacturer/Type :	FUJI 100/class II
Material:	A106GR.B / A 234 WPB	Density :	2.0 - 4.0
Welding Process :	TIGW / MMAW	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	BS 1435	Source to Object Distance :	168.3mm
Acceptance Code:	BS 1113:1999	Source Side of Object to Film Distance:	(7.11+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
SC1 - 81020								
JT.2 (WN-302)	10.11	3	168.3	7.11	0 - 1 1 - 2 2 - 0	Per NRI NRI	Reject Accept Accept	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amal Hamidi - NDT Lev.II

Date: 17 May 2018



Client Representative:

Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103693/18-09

Page No: 1 of 1

Report No: BFTT/RT-22/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd . / PT.Austindo Nusantara Jaya 35,000 KG / HR Boiler.	IQI type :	DIN FE 10-16
Job No:	BFTT 17-651	Film Manufacturer/Type :	FUJI 100/class II
Material:	A106GR.B / A 234 WPB	Density :	2.0 - 4.0
Welding Process :	TIGW / MMAW	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	BS 1435	Source to Object Distance :	168.3mm
Acceptance Code:	BS 1113:1999	Source Side of Object to Film Distance:	(7.11+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
SC1 - 81020								
JT.5 (WN-302)	10.11	3	168.3	7.11	0 - 1 1 - 2 2 - 0	Por Por Sur	Accept Accept Accept	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Date: 17 May 2018



Client Representative:

Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103693/18-09

Page No: 1 of 1

Report No: BFTT/RT-23/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd . / PT.Austindo Nusantara Jaya 35,000 KG / HR Boiler.	IQI type :	DIN FE 10-16
Job No:	BFTT 17-651	Film Manufacturer/Type :	FUJI 100/class II
Material:	A106GR.B / A 234 WPB	Density :	2.0 - 4.0
Welding Process :	TIGW / MMAW	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	BS 1435	Source to Object Distance :	168.3mm
Acceptance Code:	BS 1113:1999	Source Side of Object to Film Distance:	(7.11+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
SC1 - 81020								
JT.3 (WN-302)	10.11	3	168.3	7.11	0 - 1	NRI	Accept	
					1 - 2	NRI	Accept	
					2 - 0	NRI	Accept	

End Of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uo: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Client Representative:

Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II

Name:

Date: 17 May 2018

Date:





Our Ref. : NT/103693/18-09

Page No: 1 of 1
 Report No: BFTT/RT-24/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Bukit Fraser Thermal Technology Sdn Bhd	Procedure No:	NT/G/RT/BS EN Rev 1.0
Project :	VH Boiler And Energy System Sdn Bhd . / PT.Austindo Nusantara Jaya 35,000 KG / HR Boiler.	IQI type :	DIN FE 10-16
Job No:	BFTT 17-651	Film Manufacturer/Type :	FUJI 100/class II
Material:	A106GR.B / A 234 WPB	Density :	2.0 - 4.0
Welding Process :	TIGW / MMAW	Sensitivity:	0.32mm(Wire No.11)
Examination Code :	BS 1435	Source to Object Distance :	168.3mm
Acceptance Code:	BS 1113:1999	Source Side of Object to Film Distance:	(7.11+3)mm
Examination Date:	16 May 2018	No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
SC1 - 81020								
JT.4 (WN-302)	10.11	3	168.3	7.11	0 - 1 1 - 2 2 - 0	LF NRI LF	Reject Accept Reject	AR

_____ End Of Report _____

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uo: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II
 Interpreted & Evaluated By: Amat Hamidi - NDT Lev.II
 Date: 17 May 2018



Client Representative:
 Name:
 Date: