



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref : NT/103730/18-23

Page No: 1 of 2

Report No: NDT/RT/180592-01/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	19 April 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J1 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	
J2 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	
J3 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	

Continue Next Page

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Arc Crack	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Client Representative:

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 20 April 2018

Name:

Date:





Our Ref. : NT/103730/18-23

Page No: 2 of 2

Report No: NDT/RT/180592-01/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J4 WN-P3	6.9	3	60.3	3.9	X Y	NRI Uc	Accept Accept	
J5 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	
J6 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	
J7 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	
J8 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	
J9 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	
J10 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept Accept	



End of Report



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 1 of 2

Report No: NDT/RT/180592-02/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 333 GR 6	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	20 April 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J1	6.9	3	60.3	3.9	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
J2	6.9	3	60.3	3.9	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
J3	6.9	3	60.3	3.9	X	NRI	Accept	
WN-P3					Y	NRI	Accept	

Continue Next Page

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 21 April 2018



Client Representative:

Name:
Date:



Our Ref. : NT/103730/18-23

Page No: 2 of 2

Report No: NDT/RT/180592-02/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J4 WN-P3	6.9	3	60.3	3.9	X Y	NRI Uc	Accept	
J5 WN-P3	6.9	3	60.3	3.9	X Y	Con NRI	Accept	
J6 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept	
J7 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept	
J8 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept	
J10 WN-P3	6.9	3	60.3	3.9	X Y	NRI NRI	Accept	



End of Report



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-03/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No :	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material :	SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity :	0.20mm(2 wires visible)
Acceptance Code :	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date :	20 April 2018	Source Side of Object to Film Distance :	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J9	6.9	3	60.3	3.9	X	AR		Reshoot
WN-P3					Y	NRI	Accept	

End of Report

Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 21 April 2018



Client Representative:

Name:
Date:



RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 333 GR 6	Film Manufacturer/Type :	FUJI 100(class II)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	17 April 2018	Source Side of Object to Film Distance:	(33.4)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J1 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J2 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J3 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	

Continue Next Page

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 18 April 2018



Client Representative:

Name:
Date:



Our Ref. : NT/103730/18-23

Page No: 2 of 4

Report No: NDT/RT/180592-04/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J4 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J5 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J6 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J7 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J8 WN-P3	6.38	3	33.4	3.38	X Y Z	NSD NSD NSD	Accept Accept Accept	
J9 WN-P3	6.38	3	33.4	3.38	X Y Z	NSD NSD NSD	Accept Accept Accept	
J10 WN-P3	6.38	3	33.4	3.38	X Y Z	Por NSD NSD	Accept Accept Accept	



Continue Next Page



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 3 of 4

Report No: NDT/RT/180592-04/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J11 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	
J12 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	
J13 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	
J14 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	
J15 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	Por	Accept	
J16 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	
J17 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	



Continue Next Page



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 9, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 4 of 4

Report No: NDT/RT/180592-04/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result
J516048 Ammonia Distribution Header							
J18 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept
					Y	NSD	Accept
					Z	NSD	Accept
J19 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept
					Y	NSD	Accept
					Z	NSD	Accept
J20 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept
					Y	NSD	Accept
					Z	NSD	Accept
J21 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept
					Y	NSD	Accept
					Z	NSD	Accept
J22 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept
					Y	NSD	Accept
					Z	NSD	Accept
J23 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept
					Y	NSD	Accept
					Z	NSD	Accept

End of Report





Our Ref. : NT/103730/18-23

Page No: 1 of 3
 Report No: NDT/RT/180592-05/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	17 April 2018	Source Side of Object to Film Distance:	(33.4)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
J516048 Ammonia Distribution Header								
J24	6.38	3	33.4	3.38	X	NSD	Accept	
WN-P3					Y	NSD	Accept	
J25	6.38	3	33.4	3.38	X	NSD	Accept	
WN-P3					Y	NSD	Accept	
J26	6.38	3	33.4	3.38	X	Por	Accept	
WN-P3					Y	Por	Accept	
					Z	NSD	Accept	

Continue Next Page

Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II
 Interpreted & Evaluated By: M.Nazib - ASNT Level II
 Date: 18 April 2018

Client Representative:

Name:
Date:





Our Ref. : NT/103730/18-23

Page No: 2 of 3

Report No: NDT/RT/180592-05/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J27 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	
J28 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	
J29 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	
J30 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
J31 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
J32 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
J33 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
J34 WN-P3	6.38	3	33.4	3.38	X	NSD	Accept	
					Y	NSD	Accept	
					Z	NSD	Accept	



Continue Next Page



Our Ref. : NT/103730/18-23

Page No: 3 of 3

Report No: NDT/RT/180592-05/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J35 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J36 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J37 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J38 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J39 WN-P3	6.38	3	33.4	3.38	X Y Z	NSD NSD NSD	Accept Accept Accept	
J40 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J41 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J42 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J43 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J44 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J45 WN-P3	6.38	3	33.4	3.38	X Y	NSD NSD	Accept Accept	
J46 WN-P3	6.38	3	33.4	3.38	X Y Z	NSD NSD NSD	Accept Accept Accept	



End of Report



Our Ref. : NT/103730/18-23

Page No: 1 of 2

Report No: NDT/RT/180592-06/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	17 April 2018	Source Side of Object to Film Distance:	(33.4)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J20 WN-P3	6.38	3	33.4	3.38	X	Por	Accept	
					Y	NRI	Accept	
					Z	NRI	Accept	
J22 WN-P3	6.38	3	33.4	3.38	X	NRI	Accept	
					Y	NRI	Accept	
					Z	NRI	Accept	

Continue Next Page

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II
 Interpreted & Evaluated By: M.Nazib - ASNT Level II
 Date: 18 April 2018



Client Representative:
 Name:
 Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 2 of 2

Report No: NDT/RT/180592-06/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J23 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI Por NRI	Accept Accept Accept	
J24 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J25 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J26 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J27 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J28 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J29 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	



End of Report



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-08/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	19 April 2018	Source Side of Object to Film Distance:	(33.4)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header	6.38	3	33.4	3.38	X	NRI	Accept	
J21 WN-P3					Y	NRI	Accept	
					Z	Inc	Reject	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 20 April 2018



Client Representative:

Name:

Date:



RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client : Innovative Inspection & Services Sdn Bhd Procedure No: NT/RT/ASME Rev 7.0
Project : Sublimator 8191C1 (Saminc 3) IQI type : ASTM 1A
Material: SA 333 GR 6 Film Manufacturer/Type : FUJI 50(class I)
Welding Process : GTAW Density : 2.0 - 4.0
Examination Code : ASME V Sensitivity: 0.20mm(2 wires visible)
Acceptance Code: ASME Sect VIII Div.1 ; 2017 Ed. Source to Object Distance : 400mm
Examination Date: 19 April 2018 Source Side of Object to Film Distance: (33.4)mm
No of Radiograph(exposure) : Single Exposure
No. of Film Each Cassette : 1 Film
Radiographic Technique : DWDI
Film Viewing Technique : Double Wall Viewing
Source Type/Size : Iridium192 (3.2mm)
Location Markers : Film Side

Radiographic Examination Result

Table with 9 columns: Weld Reference (Welder No), WT (mm), RT (mm), Pipe Diameter (mm), Material Thickness (mm), Film Position, Film Interpretation, Result, Remarks. Rows include J516048 Ammonia Distribution Header and welds J30, J31, J32.

Continue Next Page

Legend:

- TI: Tungsten Inclusion, NRI: No Relevant Indication, Uc: Undercut, Por: Porosity, WT: Weld Thickness
SI: Slag Inclusion, LP: Lack of Penetration, Con: Concavity, BT: Burn Through, RT: Reinforcement Thickness
LF: Lack of Fusion, EP: Excess Penetration, AR: Artifact, Sur: Surface

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II
Interpreted & Evaluated By: M.Nazib - ASNT Level II
Date: 20 April 2018



Client Representative:
Name:
Date:



Our Ref.: NT/103730/18-23

Page No: 2 of 3

Report No: NDT/RT/180592-07/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J33 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J34 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J35 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J36 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J37 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J38 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J39 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J40 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J41 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	



Continue Next Page



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 3 of 3

Report No: NDT/RT/180592-07/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result
J516048 Ammonia Distribution Header							
J42 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept
J43 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept
J44 WN-P3	6.38	3	33.4	3.38	X Y	NRI Por	Accept Accept
J45 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept
J46 WN-P3	6.38	3	33.4	3.38	X Y Z	Por NRI NRI	Accept Accept Accept

End of Report





NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-19/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1B
Material:	SA 333 GR 6 / SA 312 TP 304L To SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	88.9mm
Examination Date:	19 April 2018	Source Side of Object to Film Distance:	(7.62+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Inlet Header								
J1	10.62	3	88.9	7.62	0-1	Por	Accept	
WN-P3					1-2	Por	Accept	
					2-0	NRI	Accept	
J2	10.62	3	88.9	7.62	0-1	NRI	Accept	
WN-P3					1-2	NRI	Accept	
					2-0	Por	Accept	
J3	10.62	3	88.9	7.62	0-1	NRI	Accept	
WN-P3					1-2	NRI	Accept	
					2-0	NRI	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 20 April 2018



Client Representative:

Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-20/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1B
Material:	SA 333 GR 6 / SA 312 TP 304L To SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	88.9mm
Examination Date:	20 April 2018	Source Side of Object to Film Distance:	(7.62+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Inlet Header								
J1	10.62	3	88.9	7.62	0 - 1	Por	Accept	
WN-P3					1 - 2	Por	Accept	
					2 - 0	NRI	Accept	
J2	10.62	3	88.9	7.62	0 - 1	NRI	Accept	
WN-P3					1 - 2	NRI	Accept	
					2 - 0	Por	Accept	
J3	10.62	3	88.9	7.62	0 - 1	NRI	Accept	
WN-P3					1 - 2	NRI	Accept	
					2 - 0	NRI	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 21 April 2018



Client Representative:

Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 3

Report No: NDT/RT/180592-09/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	20 April 2018	Source Side of Object to Film Distance:	(33.4)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J1	6.38	3	33.4	3.38	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
J2	6.38	3	33.4	3.38	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
J3	6.38	3	33.4	3.38	X	NRI	Accept	
WN-P3					Y	NRI	Accept	

Continue Next Page

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 21 April 2018



Client Representative:

Name:
Date:



Our Ref. : NT/103730/18-23

Page No: 2 of 3

Report No: NDT/RT/180592-09/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J4 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J5 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J6 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J7 WN-P3	6.38	3	33.4	3.38	X Y	NRI NRI	Accept Accept	
J8 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J9 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J10 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J11 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	
J12 WN-P3	6.38	3	33.4	3.38	X Y Z	NRI NRI NRI	Accept Accept Accept	



Continue Next Page



Our Ref. : NT/103730/18-23

Page No: 3 of 3
 Report No: NDT/RT/180592-09/18

Radlographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result
J516048 Ammonia Distribution Header							
J13 WN-P3	6.38	3	33.4	3.38	X	NRI	Accept
					Y	NRI	Accept
					Z	NRI	Accept
J14 WN-P3	6.38	3	33.4	3.38	X	NRI	Accept
					Y	NRI	Accept
					Z	NRI	Accept
J16 WN-P3	6.38	3	33.4	3.38	X	NRI	Accept
					Y	NRI	Accept
					Z	Uc	Accept
J17 WN-P3	6.38	3	33.4	3.38	X	NRI	Accept
					Y	NRI	Accept
					Z	NRI	Accept
J18 WN-P3	6.38	3	33.4	3.38	X	NRI	Accept
					Y	NRI	Accept
					Z	NRI	Accept
J19 WN-P3	6.38	3	33.4	3.38	X	NRI	Accept
					Y	Por	Accept
					Z	NRI	Accept

End of Report





NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-10/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 333 GR 6	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	20 April 2018	Source Side of Object to Film Distance:	(33.4)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Distribution Header								
J15	6.38	3	33.4	3.38	X	NRI	Accept	
WN-P3					Y	Por	Reject	
					Z	Por	Reject	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 21 April 2018



Client Representative:

Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 2

Report No: NDT/RT/180592-15/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 312 TP 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	28 March 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ1	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
CJ2	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
CJ3	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	

Continue Next Page

Legend:

Ti: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 29 March 2018



Client Representative:

Name:
Date:



Our Ref. : NT/103730/18-23

Page No: 2 of 2

Report No: NDT/RT/180592-15/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ4 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ5 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ6 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ7 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ8 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ9 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ10 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ11 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ12 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ13 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ14 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	



End of Report



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 1 of 2

Report No: NDT/RT/180592-16/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 312 TP 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	28 March 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ15	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
CJ17	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
CJ18	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	

Continue Next Page

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 29 March 2018



Client Representative:

Name:
Date:



Our Ref. : NT/103730/18-23

Page No: 2 of 2

Report No: NDT/RT/180592-16/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ19 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ20 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ21 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ22 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ24 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ25 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ26 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ27 WN-P3	5	3	60.3	2	X Y	NRI Por	Accept Accept	
CJ28 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ29 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ30 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ31 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	



End of Report



Our Ref. : NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-17/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 312 TP 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	28 March 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ23	5	3	60.3	2	X	AR		Reshoot
WN-P3					Y	NRI	Accept	

End of Report

Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 29 March 2018



Client Representative:

Name:
Date:



RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 312 TP 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	28 March 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ16	5	3	60.3	2	X	Por	Reject	
WN-P3					Y	NRI	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 29 March 2018



Client Representative:

Name:

Date:



Our Ref. : NT/103730/18-23

Page No: 1 of 3
 Report No: NDT/RT/180592-11/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 312 TP 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	20 April 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ1	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
CJ2	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
CJ3	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	

Continue Next Page

Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

Personnel Particulars

Radiographer : Emirham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 21 April 2018



Client Representative:

Name:

Date:



Our Ref. : NT/103730/18-23

Page No: 2 of 3

Report No: NDT/RT/180592-11/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ4 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ5 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ6 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ7 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ8 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ9 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ10 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ11 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ12 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	



Continue Next Page



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref : NT/103730/18-23

Page No: 3 of 3

Report No: NDT/RT/180592-11/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ13 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ14 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ15 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ17 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ18 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ19 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	AR
CJ20 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ21 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ22 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	



End of Report



Our Ref. : NT/103730/18-23

Page No: 1 of 2

Report No: NDT/RT/180592-12/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 312 TP 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	28 March 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT	RT	Pipe Diameter	Material Thickness	Film Position	Film Interpretation	Result	Remarks
	(mm)	(mm)	(mm)	(mm)				
J516048 Ammonia Tube To End Cap								
CJ24	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
CJ25	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	
CJ26	5	3	60.3	2	X	NRI	Accept	
WN-P3					Y	NRI	Accept	

Continue Next Page

Legend:

TI : Tungsten Inclusion	NRI : No Relevant Indication	Uc : Undercut	Por : Porosity	WT : Weld Thickness
SI : Slag Inclusion	LP : Lack of Penetration	Con : Concavity	BT : Burn Through	RT : Reinforcement Thickness
LF : Lack of Fusion	EP : Excess Penetration	AR : Artifact	Sur : Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 29 March 2018



Client Representative:

Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 2 of 2

Report No: NDT/RT/180592-12/18

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ27 WN-P3	5	3	60.3	2	X Y	NRI Por	Accept Accept	
CJ28 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ29 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ30 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	
CJ31 WN-P3	5	3	60.3	2	X Y	NRI NRI	Accept Accept	

End of Report





NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-13/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 312 TP 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	28 March 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ16	5	3	60.3	2	X	Por	Reject	
WN-P3					Y	NRI	Accept	

End of Report

Legend:

TI: Tungsten Inklusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inklusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 29 March 2018



Client Representative:

Name:

Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-14/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No :	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc 3)	IQI type :	ASTM 1A
Material:	SA 312 TP 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	28 March 2018	Source Side of Object to Film Distance:	(60.3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWDI
		Film Viewing Technique :	Double Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Tube To End Cap								
CJ23	5	3	60.3	2	X	AR		Reshoot
WN-P3					Y	NRI	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 29 March 2018



Client Representative:

Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref. : NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-22/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No :	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc3)	IQI type :	ASTM 1B
Material:	SA 516 GR 70	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	GTAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.33mm(5 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	12 April 2018	Source Side of Object to Film Distance:	(16+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Shell								
LS1	19	3	-	16	0 - 1	Por	Accept	
WN-P2					1 - 2	Por	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uo: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Client Representative:

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 13 April 2018

Name:

Date:





NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-23/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No:	NT/RT/ASME Rev 7.0
Project :	Sublimator 8191C1 (Saminc3)	IQI type :	ASTM 1A
Material:	SA 240 GR 304L	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	SMAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity:	0.20mm(2 wires visible)
Acceptance Code:	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date:	12 April 2018	Source Side of Object to Film Distance:	(6+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	SWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Shell LS2 WN-P31	9	3	-	6	0-1	NRI	Accept	
LS3 WN-P31	9	3	-	6	0-1	NRI	Accept	
LS4 WN-P31	9	3	-	6	0-1	NRI	Accept	
LS5 WN-P31	9	3	-	6	0-1	NRI	Accept	
LS6 WN-P31	9	3	-	6	0-1	Por	Accept	

Legend:

TI : Tungsten Inclusion
SI : Slag Inclusion
LF : Lack of Fusion

NRI : No Relevant Indication
LP : Lack of Penetration
EP : Excess Penetration

Uc : Undercut
Con : Concavity
AR : Artifact

Por : Porosity
BT : Burn Through
Sur : Surface

WT : Weld Thickness
RT : Reinforcement Thickness

End of Report

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II
Interpreted & Evaluated By: M.Nazib - ASNT Level II
Date: 13 April 2018



Client Representative:
Name:
Date:



NUSANTARA TECHNOLOGIES SDN. BHD. (187753-D)

No. 5, Jalan Anggerik Mokara 31/45, Seksyen 31, Kota Kemuning, 40460 Shah Alam, Selangor Darul Ehsan, Malaysia.

Tel: 03-5122 9766/7/8 Fax: 03-5122 8766/7 E-mail: info@nusatek.com

Our Ref.: NT/103730/18-23

Page No: 1 of 1

Report No: NDT/RT/180592-21/18

RADIOGRAPHIC EXAMINATION REPORT

Client and Testing Particulars

Client :	Innovative Inspection & Services Sdn Bhd	Procedure No :	NT/RT/ASME Rev 7.0
Project :	822QE 1 (MNA 1)	IQI type :	ASTM 1B
Material :	SA 516 GR 70	Film Manufacturer/Type :	FUJI 50(class I)
Welding Process :	SMAW	Density :	2.0 - 4.0
Examination Code :	ASME V	Sensitivity :	0.33mm(5 wires visible)
Acceptance Code :	ASME Sect VIII Div.1 ; 2017 Ed.	Source to Object Distance :	400mm
Examination Date :	18 April 2018	Source Side of Object to Film Distance :	(12.7+3)mm
		No of Radiograph(exposure) :	Single Exposure
		No. of Film Each Cassette :	1 Film
		Radiographic Technique :	DWSI
		Film Viewing Technique :	Single Wall Viewing
		Source Type/Size :	Iridium192 (3.2mm)
		Location Markers :	Film Side

Radiographic Examination Result

Weld Reference (Welder No)	WT (mm)	RT (mm)	Pipe Diameter (mm)	Material Thickness (mm)	Film Position	Film Interpretation	Result	Remarks
J516048 Ammonia Outlet								
CS08 Plus LS08 WN-P2	15.7	3	-	12.7	0 - 1	NRI	Accept	
					1 - 2	NRI	Accept	
					2 - 3	NRI	Accept	AR
					3 - 4	NRI	Accept	
					4 - 5	Por	Accept	
					5 - 0	Por	Accept	

End of Report

Legend:

TI: Tungsten Inclusion	NRI: No Relevant Indication	Uc: Undercut	Por: Porosity	WT: Weld Thickness
SI: Slag Inclusion	LP: Lack of Penetration	Con: Concavity	BT: Burn Through	RT: Reinforcement Thickness
LF: Lack of Fusion	EP: Excess Penetration	AR: Artifact	Sur: Surface	

Personnel Particulars

Radiographer : Emirsham - NDT Lev. II

Interpreted & Evaluated By: M.Nazib - ASNT Level II

Date: 19 April 2018



Client Representative:

Name:
Date: